

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 104/RWS

Dated: 03/7/2024

It is certified that an inspection team headed by Assistant Engineer, R.W.S. Birbhum
Sub-Division, PHE Dte.
(Name of Officers with designation) from Madhab Kumar Singha, AE (RWS), PHE
Dte, Govt of WB
(Name of Department/ Office) inspected the Snehalata Public School, Karnahtar
Birbhum, 731302
(Name & Address of the school) on 01/07/24 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 (one) year



Signature with Seal: Assistant Engineer
R.W.S. Birb-Sub-Divn.
P.H.E. Dte

Name : Madhab Kumar Singha

Designation : Assistant Engineer, RWS
Birbhum Sub Division, PHE Dte.

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To
SNEHALATA PUBLIC SCHOOL
KARNATHAR, BIRBHUM, 731302

(Name & Address of the Institution)

o/o The Assistant Engineers
RWS, Birbhum Sub-Division
PHE, Dte.
PO Suri, Dist- Birbhum,
731167, WB

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Har Ghar Jal
Jal Jeevan Mission

Birbhum District Water Testing Laboratory

Office of the Executive Engineer, Birbhum Division P.H. Engineering Dte.
P.H.E. Complex, S.P. More, Post: Suri, District: Birbhum, Pin: 731101
Email: birbhumdistrictlab@gmail.com



TEST REPORT

Issued to: Snehalata Public School	Work order Number: N/A
	Date: N/A
Source Location: Kirnahar , Birbhum, 731302.	GRN Number: 192024250070435068
	Date: 07.06.2024
Name of PWSS: N/A	Sample Id No: BDWTL/02/July/ 2024
Type of Source: Submersible	Sample Collected By: Monojit Nath (Sampling Assistant)
Date of Collection: 01.07.2024	Test Completion Date: 02.07.2024

CHEMICAL & BACTERIOLOGICAL TEST RESULTS

Sl. No.	Test Parameters	Unit	Test Methods	Requirement (Acceptable Limit)	Permissible Limit in the absence of alternate Source	Results
				As per IS 10500 : 2012		
1.	pH	---	IS 3025 (Part 11) : 2022 Electrometric method	6.5-8.5	6.5-8.5	7.12
2.	Total Dissolved Solid	mg/L	By TDS Meter	500	2000	284
3.	Turbidity	NTU	IS 3025 (Pt 10) : 2023 Nephelometric Turbidity Meter	1.00	5.00	4.62
4.	Fluoride	mg/L	APHA 24th Edition,4500FC;2023 Ion Selective Electrode Method	1.0	1.5	0.109
5.	Total Hardness	mg/L	IS 3025 (Part 21) :2009 RA 2019 EDTA Titrimetric Method	200	600	196
6.	Iron	mg/L	Spectrophotometric Kit Method	1.0	No Relaxation	0.1
7.	Manganese	mg/L	Spectrophotometric Kit Method	0.1	0.3	0.01
8.	TC	CFU	IS 15185:2016 ISO 9308-1:2014 Membrane Filter Technique Method	Shall not be detectable in any 100 ml of sample		0
9.	FC	CFU	IS 15185:2016 ISO 9308-1:2014 Membrane Filter Technique Method	Shall not be detectable in any 100 ml of sample		0

[Signature]
3/7/24

Bacteriologist
Birbhum Division
P.H.E Dte.

Bacteriologist
District W.T. Laboratory

[Signature]
8/7/24

Chemist
Birbhum Division
P.H.E Dte.

Chemist
District W.T. Laboratory

[Signature]
04/07/24

Junior Engineer
Birbhum Division

P.H.E Dte.
Junior Engineer
Birbhum Division, P.H.E Dte
Suri, Birbhum

[Signature]
03/07/2024

Assistant Engineer (RWS)
Birbhum Sub-Division
P.H.E Dte.

Assistant Engineer
R.W.S. Birbhum Sub-Divn
P.H.E Dte. Suri